



INSPECTION REPORT

1451 cust_id
313050 insp_id
4189 site_id

**UNIVERSITY OF LOUISIANA AT
LAFAYETTE**

**Customer ID: 1451
Certificate: 72-R-0007**

**PO BOX 41008
LAFAYETTE, LA 70504**

**Site: 001
UNIVERSITY OF LOUISIANA AT**

**Inspection
Type: ROUTINE INSPECTION
Date: MAY-23-2007**

3.75 (f)

HOUSING FACILITIES, GENERAL.

(f) Drainage and waste disposal. Housing facility operators must provide for regular and frequent collection, removal, and disposal of ...water, and any other fluids and wastes, in a manner that minimizes contamination and disease risk. Housing facilities must be equipped with disposal facilities and drainage systems that are constructed and operated so that animal wastes and water are rapidly eliminated and the animals stay dry. Disposal and drainage systems must minimize vermin and pest infestation, insects, odors, and disease hazards. All drains must be properly constructed, installed, and maintained. ...Standing puddles of water in animal areas must be mopped up or drained so that the animals remain dry.

Outdoor corrals housing Rhesus macaques have chain link chutes on concrete pads in the rear of the primary enclosures. These chutes are used for capturing animals for medical evaluations. There is a metal rim for support of chain link around the perimeter of the concrete pad. This design facilitates retention of water in this area and there is standing water on the concrete pads of at least 3 enclosure areas at the time of inspection. These areas must be configured to allow rapid drainage of water to allow animals to remain dry at time of capture and to minimize water sources for vermin. Correct by: 6-30-07

3.80 (a) (2) (ix)

PRIMARY ENCLOSURES.

General Requirements - Primary enclosures for non human primates must be constructed and maintained so they can enable all surfaces in contact with the non human primates to be readily cleaned and sanitized in accordance with Section 3.84 (b)(3) of this subpart.

Indoor/Outdoor facility housing approximately 28 Chimpanzees in an area designated as Room 101 in Building 10 has peeled paint and pitted concrete surfaces which preclude adequate cleaning and sanitation. This can be harmful to the Chimps housed within by serving as a reservoir for disease agents which would be killed with proper sanitation. Correct by: 7-30-07

Indoor macaque housing areas of buildings 45 (rooms 3 and 4) and building 43 (rooms 2 and 3) have foci of peeling paint and pitting of the floors. This inhibits proper cleaning and sanitation of this surface. Correct by: 7-30-07

The ceiling of room 2 building 43 has areas of peeling and flaking paint. Paint chips can fall into animal enclosures and pose a health risk to animals if ingested. This also inhibits proper cleaning and sanitation of this surface. Correct by: 7-30-

Prepared By: *Lynn P. Bourgeois, Amy Beathelarrow, DVM*
LYNN BOURGEOIS, V.M.O. , USDA, APHIS, Animal Care

JUN - 4 2007

Title: [Redacted]
Received By: [Redacted]
Title: [Redacted]

Date:
MAY-23-2007

Date:
MAY-23-2007



INSPECTION REPORT

1451 cust_id
313050 insp_id
4189 site_id

07

These areas need to be renovated and surfaces rendered sanitizable.

COMPLETE INSPECTION CONDUCTED 22-24 MAY 2007.

Prepared By: *Lynn P Bourgeois*
LYNN BOURGEOIS, V.M.O., USDA, APHIS, Animal Care

JUN - 4 2007

Title:

Date:
MAY-23-2007

Received By:

Title:

Date:
MAY-23-2007

