



**INSPECTION REPORT**

**EMORY UNIVERSITY**

Customer ID: 896

Certificate: 57-R-0003

Site: 003

EMORY UNIVERSITY

WOODRUFF HLTH SCIENCES CTR, 1440 CLIFTON RD NE  
ATLANTA, GA 30322

Inspection

Type: ROUTINE INSPECTION

Date: FEB-22-2007

**3.75**

**HOUSING FACILITIES, GENERAL.**

(a) Structure, construction. Housing facilities for nonhuman primates must be designed and constructed so that they are structurally sound for the species of nonhuman primates housed in them. They must be kept in good repair...

\*\*\*Caulk used for sealing ceilings and walls is peeling loose in several areas. In the small primate wing (236) the caulk seal is pulling loose from the lower edge of the rear wall. Strands of caulk were hanging from the ceiling in D115, D116, D117, and D128. Additionally, a ceiling panel divider in room D115 is separating from the ceiling as a result of the defective caulk. The ceilings in these areas must be assessed to ensure integrity of ceilings. Additionally, the strands of loosened caulk present an animal hazard if they fall into animal enclosures. Correct by: 30 Apr 07.

\*\*\*One light fixture in IDB 104 is becoming detached from the ceiling. The fixture must be secured and the ceiling integrity in this area assessed for safety. Correct by: 30 Apr 07.

**3.76 (c)**

**INDOOR HOUSING FACILITIES.**

(c) Lighting. ...Lighting must be uniformly diffused throughout animal facilities and provide sufficient illumination to aid in maintaining good housekeeping practices, adequate cleaning, adequate inspection of animals, and for the well-being of the animals.

\*\*\*2 banks of lights directly above the animal enclosure in RB12 (1 chimpanzee) are not functioning. Lighting in animal areas must be uniformly diffused. Correct by: 01 Mar 07.

**3.84 (c)**

**CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.**

(d) Pest control. An effective program for control of insects, external parasites affecting nonhuman primates, and birds and mammals that are pests, must be established and maintained so as to promote the health and well-being of the animals and reduce contamination by pests in animal areas.

\*\*\*Roaches are noted in rooms 242 (small primate wing), and V153-160 evidenced by live roaches noted and excessive dead roaches in light fixtures. Roach traps have been placed inside light covers since last inspection; however, the traps have not been effective in maintaining pest control in these areas. Correct by: 30 Apr 07.

\*\*\*Black sewer flies are noted in NS hallway adjacent to cagewash and in room 1248. Means to minimize pests must be implemented and maintained. Correct by: 30 Apr 07.

Prepared By:

*Amy Bartholomew*  
AMY BARTHOLOMEW, D.V.M., USDA, APHIS, Animal Care

Title

Received By

Title

Date:

FEB-23-2007

Date:

FEB-23-2007



JUN 26 2007

### INSPECTION REPORT

**EMORY UNIVERSITY**

Customer ID: 896

Certificate: 57-R-0003

Site: 001

EMORY UNIVERSITY

WOODRUFF HLTH SCIENCES CTR, 1440 CLIFTON RD NE  
ATLANTA, GA 30322

Inspection

Type: ROUTINE INSPECTION

Date: JUN-06-2007

#### 2.31 (d)(1)(ix)

##### INSTITUTIONAL ANIMAL CARE AND USE COMMITTEE (IACUC).

(d) IACUC review of activities involving animals.

(Also refer to Policy 16, Dealers Selling Surgically-Altered Animals to Research)

(1) ...IACUC shall determine that the proposed activities or significant changes in ongoing activities meet the following requirements:

(ix) ...Major operative procedures on non-rodents will be conducted only in facilities intended for that purpose which shall be operated and maintained under aseptic conditions.

\*\*\*Rollins room G18 currently utilized for ovine and porcine operative procedures has an excessively dirty blanket for animal use stored in the procedure area. The blanket is folded and stored on the shelving adjacent to the procedure table. This blanket has areas of dried, caked fecal material on it. Items utilized in animal procedure rooms must be either disposable or must be able to be effectively cleaned and sanitized. Soiled materials stored in procedure areas inhibit maintenance of aseptic conditions. Correct by: 08 Jun 07.

#### 3.51 (c)

##### FACILITIES, INDOOR.

(d) Interior surfaces. The interior building surfaces of indoor housing facilities shall be constructed and maintained so that they are substantially impervious to moisture and may be readily sanitized.

\*\*\*The floor of the Rollins rabbit room containing 4 rabbits has multiple small (less than 1 cm) pits in the flooring. Indoor housing surfaces must be maintained in a manner that allows proper cleaning and sanitization. Correct by: 01 Aug 07.

\*\*\*The lower portion of the rear wall of Eye Center Building rooms ET410 and BT 408 is damaged. There is flaking paint and black discoloration of the wall in this area. Rabbit rooms must be maintained in a manner that allows proper cleaning and sanitization. Correct by: 01 Aug 07.

Prepared By:

*Amy Bartholomew, DVM*  
AMY BARTHOLOMEW, D V M, USDA, APHIS, Animal Care

Title:

Received By:

Title:

Date:

JUN-06-2007

Date:

JUN-06-2007

JUN 26 2007

## INSPECTION REPORT

896 cust\_id  
200647 insp\_id  
7800 site\_id

### 3.56 ( c )

#### SANITATION.

(c) Housekeeping. Premises (buildings and grounds) shall be kept clean and in good repair in order to protect the animals from injury and to facilitate the prescribed husbandry practices set forth in this subpart.

\*\*\*Eye Center Building room BT41 (feed storage area for rabbits) has minimally functional lighting. The lighting in this area is too dim to facilitate standard husbandry practices. Correct by: 11 Jun 07.

\*\*\*Pediatrics Building room G29 has a leaking watering system near the primary enclosure for one rabbit (bottom left corner of rack). This has resulted in standing water beneath the rack and soaking of the catch pan beneath the primary enclosure. Correction implemented at time of inspection. Correct by: 07 Jun 07.

### 3.125 ( a )

#### FACILITIES, GENERAL.

(a) Structural strength. The facility must be constructed of such material and of such strength as appropriate for the animals involved. The indoor and outdoor housing facilities shall be structurally sound and shall be maintained in good repair to protect the animals from injury and to contain the animals.

\*\*\*One primary enclosure housing 2 pigs has damaged chain link on the cage front. There is a piece of wire protruding toward the animals that poses risk of animal injury. The enclosure must be replaced or repaired to eliminate the sharp area. Correct by: 08 Jun 07.

#### Reviewed:

- 1.) Record of Animals on Hand (cats)
- 2.) Animal weights ("Pogo" and "Naz")
- 3.) Discussed appropriate labeling of laboratory items

Prepared By:

*Amy Bartholomew, DVM*  
AMY BARTHOLOMEW, D V M , USDA, APHIS, Animal Care

Title:

Received By:

Title:

Date:

JUN-06-2007

Date:

JUN-06-2007



**INSPECTION REPORT**

**EMORY UNIVERSITY**

Customer ID: 896

Certificate: 57-R-0003

Site: 002

EMORY UNIVERSITY

**WOODRUFF HLTH SCIENCES CTR, 1440 CLIFTON RD NE  
ATLANTA, GA 30322**

Inspection

Type: ROUTINE INSPECTION

Date: DEC-11-2007

**3.80 (a)(1)(ix)**

**PRIMARY ENCLOSURES.**

Primary enclosures for nonhuman primates must meet the following minimum requirements:

(a) General requirements.

(2) Primary enclosures must be constructed and maintained so that they:

(ix) Enable all surfaces in contact with nonhuman primates to be readily cleaned and sanitized in accordance with §3.84(b)(3) of this subpart, or replaced when worn or soiled

\*\*\*Floors of indoor quarters of D1/D2, and T3 are cracking in the area around the gutter drains. The floor of the interior of T2 is cracking in the gutter and there is an area in A where the floor surface has a large chip along the mid-front section of the gutter wall adjacent to the animal enclosure. There is exposed porous surface beneath that cannot be properly cleaned and sanitized. The floors must be repaired or replaced so that the surface can be properly cleaned and sanitized. Correct by: 01 Feb 08.

**3.84 (c)**

**CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.**

(c) Housekeeping for premises. Premises where housing facilities are located, including buildings and surrounding grounds, must be kept clean and in good repair in order to protect the nonhuman primates from injury, to facilitate the husbandry practices required in this subpart, and to reduce or eliminate breeding and living areas for rodents, pests, and vermin.

\*\*\*There is an established raccoon latrine on the observation tower behind the S-compound (overlooks S 3/4 and S7/8). Facilities must be maintained under sanitary conditions for animals and staff. Raccoons are known carriers of zoonotic diseases and parasites. Facilities, including surrounding grounds, must be maintained to eliminate living areas for pests. Correct by: 01 Jan 08

\*\*\*There are roaches (live and dead) trapped on the lamp cover of the indoor portion of S1. Dead roaches have accumulated inside the lamp covers. Effective pest control must be maintained or updated light fixtures (similar to those in use in other areas of the facility) should be installed. Correct by: 15 Jan 08.

Prepared By:

*Amy Bartholomew, DVM*  
AMY BARTHOLOMEW, D V M , USDA, APHIS, Animal Care

Date:

DEC-11-2007

Title:

Received By:

Title:

Date:

DEC-11-2007